



Infection Control Construction Site Monitoring Tool

Project Type: Construction Renovation Maintenance

Preventive Measures: I II III IV

Project Name:

Project Location:

Regional IP&C Coordinator or Infection Control Practitioner:

Date:

| Compliance | Yes | No | N/A =Not applicable N/O = Not observed | Comments |
|--|-----|----|---|----------|
| Barriers | | | | |
| Construction signs posted for the area | | | | |
| Doors properly closed and sealed | | | | |
| Floor area clean, no dust tracked | | | | |
| Walk off mats moist/sticky | | | | |
| Tape adhering to surface | | | | |
| Hoarding intact | | | | |
| Air Handling | | | | |
| All windows closed behind barrier | | | | |
| Negative air at barrier entrance | | | | |
| Negative air machine running and current maintenance label visible | | | | |
| HEPA filter and pre-filters are clean. Record date of last filter change | | | | |
| Air exhausted to appropriate area/outside | | | | |
| Project Area | | | | |
| HEPA filter-equipped vacuum on site | | | | |
| Debris removed in covered container daily | | | | |
| Designated route used for debris removal | | | | |
| Trash in appropriate container | | | | |

| | | | | |
|--|--|--|--|--|
| Routine cleaning done on job site | | | | |
| Air vents sealed/duct work capped/drains covered | | | | |

Traffic Control

| | | | | |
|---|--|--|--|--|
| Restricted to construction workers and necessary staff only | | | | |
| All doors and exits free of debris | | | | |

Dress Code

| | | | | |
|--|--|--|--|--|
| Appropriate for the area (i.e. OR, CSR, L&D, etc.) | | | | |
| Required to enter | | | | |
| Required to leave | | | | |
| Protective clothing required in work space | | | | |
| Workers clothing clean on exiting workspace | | | | |

Deficiencies reported to:

Date:

Corrective measures: describe what and by whom:

Regional IP&C Coordinator or ICP: _____